

Vehicle-to-Grid Power Economics from a Fleet Perspective

Jasna Tomic

Consultant, WestStart-Calstart


and

Fellow, University of Delaware


Outline

- V2G power for Ancillary Services
- What are Ancillary Services
- Cost and Revenue Calculations
- Sample results of 2 actual EDV fleet cases
- Potential for Seattle City Light Fleet
- Summary and Conclusions

USES FOR V2G POWER



Ancillary Services



- Maintain grid reliability
- Balance Supply and Demand
- Support transmission of electric power
- AS requirements 5-10% of the system load

Providing Ancillary Services

- Grid Operators require utilities to self-provide A/S
- Competitive A/S markets (ISO regions)
- In Pacific NW — Case 1
- Will draw from other market experiences

Ancillary Services

- Regulation: On-line generation synchronized to the grid to keep frequency and voltage steady. Energy is increased/decreased instantly (~ 2-3 min) via automatic generation control (AGC)
- Spinning Reserves: Additional generating capacity synchronized with system to respond ~10 min in case of failures.
- Payments consist of:
Capacity price (\$/MW-h) + Energy price (\$/MWh)

Utility EDV Fleets for Regulation

UTILITY EDV FLEETS

- Utility EDV fleets already exist (battery EDV)
- Have a predictable schedule
- Utilities are familiar with A/S

REGULATION and SPINNING RESERVES

- High value energy markets
- Compatible with battery EDVs

Cost and Revenue Regulation

$$r_{Reg} = (p_{cont} \cdot P \cdot t_{plug}) + (p_{el} \cdot P \cdot t_{plug} \cdot R_{d-c})$$

$$c_{Reg} = (c_{en} \cdot P \cdot t_{plug} \cdot R_{d-c}) + c_{ac}$$

p_{cont}	contract price for regulation (\$/kW-h)
P	power capacity (kW)
t_{plug}	availability of vehicles as fraction of day
R_{d-c}	energy dispatched as proportion of contracted power
p_{el}	market selling price of electricity (\$/kWh)
c_{en}	cost to produce energy (\$/kWh)
c_{ac}	annualized capital cost for V2G (\$)

Cost and Revenue Spinning Reserves

$$r_{Spin} = (p_{cont} \cdot P \cdot t_{plug}) + (p_{el} \cdot P \cdot t_{plug})$$

$$c_{Spin} = (c_{en} \cdot P \cdot t_{plug}) + c_{ac}$$

p_{cont}	contract price for regulation (\$/kW-h)
P	power capacity (kW)
t_{plug}	availability of vehicles as fraction of day
R_{d-c}	energy dispatched as proportion of contracted power
p_{el}	market selling price of electricity (\$/kWh)
c_{en}	cost to produce energy (\$/kWh)
c_{ac}	annualized capital cost for V2G (\$)

Power Capacity

Spinning Reserves

$$P_{vehicle} = \frac{\left(E_s - \frac{d_d + d_{rb}}{\eta_{veh}} \right) \cdot \eta_{inv}}{t_{disp}}$$

Regulation

$$P_{line} = 15 \text{ kW}$$

240 V, 50 amp

P_{line} — power capacity line (kW)

$P_{vehicle}$ — power capacity vehicles (kW)

d_d — distance driven (mi)

d_{rb} — range buffer (mi)

η_{veh} — efficiency vehicle (mi/kWh)

η_{inv} — efficiency inverter

t_{disp} — time dispatched (h)

Energy Cost

$$c_{en} = \frac{c_{el}}{\eta_{GBG}} + c_d \quad c_d = \frac{c_{bat}}{E_{LT}} = \frac{(E_s \bullet c_b) + (c_l \bullet t_l)}{L_C \bullet E_s \bullet DoD}$$

E_s – energy stored on-board (kWh)

c_b – cost of battery replacement (\$/kWh)

c_l – cost of labor (\$/h)

t_l – labor for battery replacement (h)

DoD – depth of discharge allowed

L_C – battery life in cycles

η_{GBG} — efficiency grid-battery-grid

Three Fleet Cases

- **New York Station Cars — 100
Th!nk City**



- **CA Utility Fleet — 252 RAV4 EDV**



- **Seattle City Light — 250 Toyota
Scion EDV**



Fleet Case A

New York Station Cars

100



- For regulation services
- Upgrade cost for V2G included
- $P_{\text{line}} = 6.2 \text{ kW}$
- $t_{\text{plug}} = 23 \text{ h}$
- $c_{\text{el}} = 0.05 \text{ \$/kWh}$, $c_{\text{en}} = 0.16 \text{ \$/kWh}$
- NY ISO Regulation Capacity price
 $P_{\text{contr}} = 27.5 \text{ \$/MW-h}$ (2003)

Calculated Profits

Case A

In 2003			
FLEET POWER kW	Cost	Revenue	Net Profit
620	\$ 99,500	\$ 311,700	\$ 212,200

252

Fleet Case B

Utility EDV Fleet



- For regulation services
- Upgrade costs for V2G included
- $P_{\text{line}} = 15 \text{ kW}$
- $t_{\text{plug}} = 17 \text{ h}$
- $c_{\text{el}} = 0.05 \text{ \$/kWh}$, $c_{\text{en}} = 0.15 \text{ \$/kWh}$
- CAISO Regulation Capacity price (2003)
 - $\text{Reg}_{\text{up}} \quad p_{\text{contr}} = 19.5 \text{ \$/MW-h}$
 - $\text{Reg}_{\text{down}} \quad p_{\text{contr}} = 20.3 \text{ \$/MW-h}$

Calculated Profits

Case B

	In 2003		
FLEET POWER kW	Cost	Revenue	Net Profit
@15 kW 3,780	\$380,000	\$1,039,000	\$659,000

250



Seattle City Light Potential Fleet

- For spinning reserves
- V2G ready !
- $P_{\text{veh/line}} = 15 \text{ kW}$
- $t_{\text{plug}} = 16 \text{ h}$
- $c_{\text{el}} = 0.05 \text{ \$/kWh}$, $c_{\text{en}} = 0.22 \text{ \$/kWh}$
- Spinning Reserves Capacity price
 $P_{\text{contr}} = 7.39 \text{ \$/MW-h (2005)}$

Spinning Reserves Potential Profits

Seattle City Light Fleet

In 2003			
FLEET POWER kW	Cost	Revenue	Net Profit
@ 15 kW 3,750	\$ 17,000	\$ 165,500	\$ 148,500

Regulation Profits Could be Higher

Markets	Spinning Reserves (\$/MW-h)	Regulation (\$/MW-h)
NY ISO	5.3	27.5
CA ISO	7.1	19.5
Pacific NW (Seattle)	7.4	?

Summary

3 fleet case analyses in different markets show significant economic potential for V2G providing A/S

- Fleet of 100 small EDVs in NY
Revenue of \$200,000
- Fleet of 250 EDVs in CA
Revenue of \$660,000
- Fleet of 250 EDVs in Seattle
Revenue of \$150,000

Important parameters:

- market value of A/S
- kW capacity of vehicles and electrical connections
- kWh capacity of vehicle battery

Conclusions for Fleets

- EDVs are promising sources of grid power
- V2G has high market value for regulation services and spinning reserves
- Utility fleets can be early adopters of V2G technology

Conclusions for V2G

- V2G provides a link between the electric power system and vehicle fleets
- V2G introduces the dual use of vehicles — for transportation and power generation
- Benefits — clean transportation (no CO₂) and clean source of electric power

Acknowledgments

**Funded in part by Kirsch Foundation
and Conectiv Power Delivery**